

# VOC Content Test Certificate

Tuesday, 4<sup>th</sup> July 2018

Supplier: Ssangkom Pty Ltd (Unit 7 & 8 / 225A Brisbane Road, Biggera Waters, QLD, 4216)

Sample Description: SSANGKOM DRYFIX I

Date Tested: June 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.1 13.1.1</b> <b>Green Star Interiors V1.1 12.1.1B</b>	<b>SSANGKOM DRYFIX I</b>
General Purpose Adhesives and Sealants: 60 grams per Litre as VOC content per material	<b>2 grams per Litre as VOC content</b>
<p><i>We hereby certify that Ssangkom Dry Fix I is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

CV180621A